





BALIM



A	B	C	D1-D2	E	HEAT	HEAT
HEIGHT	LENGTH	PIPE CENTER	VERTICAL BRACKET CENTERS	HORIZONTAL BRACKET CENTERS	OUTPUTS (BTU)	OUTPUTS (WATT)
mm	mm	mm	mm	mm	Delta T:50 °C	Delta T:50 °C
1400	785	50	280-280	162	1998	585
1120	785	50	280-280	162	1554	455
840	785	50	120-160	162	1110	325
580	550	50	-	-	666	195



Bracket Assembly

